

**BUREAU OF FIRE PREVENTION
FIRE DISTRICT #2
TOWNSHIP OF OLD BRIDGE
732-970-6542 PHONE
732-970-6545 FAX**

8:00 – 4:00 OFFICE HOURS

IF MONITORED ALARM, SOMEONE MUST BE ON SITE WITH CODE TO PUT THE ALARM ON TEST. ALSO, A LEGAL ADULT MUST BE PRESENT DURING THE INSPECTION. THE INSPECTORS DO NOT GO INTO VACANT PREMISES.

YOUR APPOINTMENT HAS BEEN SCHEDULED FOR _____ FROM _____.

**ONE & TWO FAMILY DWELLING
SMOKE DETECTOR/CARBON MONOXIDE
FIRE EXTINGUISHER REQUIREMENTS**

- **1 SMOKE DETECTOR, 10 YEAR SEALED BATTERY POWER ON EACH LEVEL, INCLUDING BASEMENT**
- **1 SMOKE DETECTOR WITHIN 10 FEET OF BEDROOMS. IF AT THE TIME OF HOME CONSTRUCTION SMOKE DETECTORS WERE HARD-WIRED AND/OR INTERCONNECTED, THEY MUST REMAIN THAT WAY (I.E. DO NOT REPLACE WITH BATTERY DETECTORS).**
- **1 CARBON MONOXIDE DETECTOR WITHIN 10 FEET OF BEDROOMS, CAN BE BATTERY OR PLUG-IN**
- **1 FIRE EXTINGUISHER RATED FOR RESIDENTIAL USE – 2A:10B:C – WITHIN 10 FEET OF KITCHEN, MUST BE MOUNTED NO HIGHER THAN 5 FEET FROM FLOOR, CANNOT WEIGH ANYMORE THAN 10 LBS. (NOT IN CABINET, BEHIND DOOR)**
- **FAILURE FOR ANY REASON WILL REQUIRE YOU TO MAKE AN ADDITIONAL APPOINTMENT FOR REINSPECTION BY CALLING THE OFFICE**
- **ALL REINSPECTIONS WILL REQUIRE AN ADDITIONAL \$35.00 FEE**