

**Bureau of Fire Prevention**  
**Fire District #2**  
**Township of Old Bridge**  
[info@obfd2.com](mailto:info@obfd2.com)



**3098 Highway 516**  
**Old Bridge, NJ 08857**  
**Phone: 732-970-6542**

**APPOINTMENT DATE:** \_\_\_\_\_ **TIME:** \_\_\_\_\_

**SINGLE FAMILY DWELLING**  
**CERTIFICATE OF SMOKE ALARM, CARBON MONOXIDE ALARM, AND PORTABLE FIRE**  
**EXTINGUISHER COMPLIANCE**

Below are the basic requirements to receive a certificate. These are **ONLY** the basic requirements and **do not include** all requirements as per all applicable codes and standards.

- All fire alarms that were approved on the CO from the Township of Old Bridge Building and Code Enforcement must be operational and installed according to the CO (certificate of occupancy). This may include any AC, AC/battery backup, and interconnected smoke alarms.
- If fire alarms were not required as part of the CO in **all** the designated locations listed above, 10-year sealed battery smoke alarms shall be installed.
  - A smoke alarm shall be installed on **every** level of the occupancy including the basement.
  - A smoke alarm is required within 10 feet of **all** sleeping areas/bedrooms.
- **All** smoke alarms over 10 years of age must be replaced.
- A carbon monoxide detector is required within 10 feet of **all** sleeping areas/bedrooms.
  - The carbon monoxide detector can be either AC or battery operated.
- A portable fire extinguisher is required to be installed within 10 feet of the kitchen and located in the path of egress. The top of the extinguisher shall not be more than 5 feet above floor level.
  - The extinguisher shall be an approved listed and labeled, with a minimum rating of **2A-10B:C**
  - The extinguisher shall be mounted using the manufacturers hanging bracket so that the operating instructions of the extinguisher are clearly visible. The extinguisher shall be readily accessible and not obstructed from view.

**ALL APPOINTMENTS ARE SCHEDULED BETWEEN THE HOURS OF 8:00 AND 10:00 AM. ALL OF OUR INSPECTORS ARE FIREFIGHTERS THAT RESPOND TO EMERGENCIES, FOR THIS REASON WE CAN NOT GIVE YOU AN EXACT TIME FOR THE INSPECTION. AN ADULT OVER THE AGE OF 18 MUST BE PRESENT AT TIME OF INSPECTION**

Thomas D. Miller  
Fire Officer 1  
Fire District #2  
Old Bridge, N.J. 08857